



SAFETY AND BUILDINGS DIVISION  
Plumbing Product Review  
P.O. Box 2658  
Madison, Wisconsin 53701-2658  
**TTY: Contact Through Relay**

**Scott Walker, Governor**  
**Dave Ross, Secretary**

October 4, 2011

SIM / TECH FILTER  
KOTESKEY BROTHERS EXCAVATING INC.  
GARY KOTESKEY  
06598 HORTON BAY N RD.  
BOYNE CITY MI 49712

Re: Description: SEWAGE TANK COVERS, LIDS, RISERS  
Manufacturer: SIM / TECH FILTER  
Product Name: RISER AND RELATED PARTS  
Model Number(s): STF-R824 RISER; STF-CI24 CAST IRON COVER; STF-APC24B or STF-APC24G  
POLYCARBONATE COVER; STF-AR24 TANK ADAPTER RING; and STF-N24 SECURITY  
NET W/MOUNTING HARDWARE  
**(STACKABLE 8-IN. HIGH RISERS, FIELD MODIFIED 2-4 IN. HEIGHT)**  
Product File No: 20110294

The specifications and/or plans for this plumbing product have been reviewed and determined to be in compliance with chapters Comm 82 through 84, Wisconsin Administrative Code, and Chapters 145 and 160, Wisconsin Statutes.

The Department hereby issues an approval based on the Wisconsin Statutes and the Wisconsin Administrative Code. **This approval is valid until the end of October 2016.**

This approval is contingent upon compliance with the following stipulation(s):

- This product must be installed in accordance with the manufacturer's installation instructions and the following requirements:
  1. Mechanical fasteners must be used to mount the STF-AR24 Adapter Ring to top of tank.
  2. Silicone rubber sealant must applied to the horizontal joint between riser sections.
  3. A minimum of three 1 to 1-1/4 inch #8 or #10 stainless steel screws must be used to secure the bottom and top riser sections together. The screws must be equally spaced around the riser.
  4. Risers must be backfilled with sand or installed with a frost shield.
  5. An acceptable locking device must be used to secure riser cover.

This approval supersedes the approval issued on 7/23/2008 under product file number 20060348.

This approval letter shall be incorporated with your previously approved plans and/or specifications approved under product file number 20060348.

The department is in no way endorsing this product or any advertising, and is not responsible for any situation which may result from its use.

Sincerely,

Jean M. MacCubbin, CST  
Engineering Consultant--Plumbing Products Review  
DPS WEST, Safety & Buildings Div.  
PO Box 2658  
201 W Washington Ave.  
Madison WI 53703-2658  
Phone: 608-266-0955; Fax: 608-283-7456  
E-mail: Jean.MacCubbin@WI.GOV